

Classification according to standard prEN 45545 part 2 (2010)
Railway application – Fire protection on railway vehicles –
Part 2: Requirements for fire behaviour of materials and components

Applicant: **3M TILTON**
1 Paper Trail
USA - Tilton, N.H.

Product: **THERMA VOLT**

Product description: high temperature paper
thickness: 0.127 mm; weight: 186 g/m²; density: 1506 kg/m³.

Listed Item: electrical insulation

Requirements **R 23**

Tables of results:

EN ISO 4589-2 Report LSFire 02242 Oxygen Index		EN ISO 5659-2 25 kW/m ² + PF Report LSFire 02243 Smoke		EN ISO 5659-2 25 kW/m ² + PF Report LSFire 02243 Toxicity	
% (V/V)	Class	Ds max	Class	CIT _C	Class
93.4	HL 3	2.54	HL 3	0.0045	HL 3

Remarks: The value of CIT index was calculated using the test method EN ISO 5659-2 instead of NF X 70-100-1/2 according to prEN 45545-2.

Final classification

HL3

Controguerra, 04-05-2012

LABORATORY DIRECTOR
Maddalena Pezzani

This document is composed by n°1 page and it can be reproduced only on the whole.
Enclosure: Technical data sheet supplied by the Applicant.

TEST REPORT
according to :

LSFIRE/NC02242
Date: 24-04-2012

EN ISO 4589 - 2

Determination of burning behaviour by oxygen index

for

prEN 45545-2 Fire protection of railway vehicle
Part 2 - Requirements for fire behaviour of materials and components

Applicant: **3M TILTON**
1 Paper Trail
USA - Tilton, N.H.

Denomination of the product : **THERMA VOLT**

Description and characteristics : high temperature paper
thickness: 0.127 mm; weight: 186 g/m²; density: 1506 kg/m³.

Use : electrical insulation

Conditioning: T = (23 ± 2)°C and R.H. = (50 ± 5)% for 88h minimum

SUMMARY OF RESULTS

Characteristics	Units	Value
Type of test specimen	-	V
Test specimen dimensions	(mm)	140 × 52 × 0.127
Ignition procedure used	-	B
Used O ₂ concentration increment	% (V/V)	0.2
Final value of O ₂ concentration - c _f	% (V/V)	93.2
k factor	-	0.95
Standard deviation	σ	0.15
Measured Oxygen Index - OI	% (V/V)	93.4

Note:

These results relate only to the behaviour of the product under the conditions of test method.
They are not intended to be the sole criterion for the assessment of the performance under real fire conditions.

Controguerra, 04-05-2012

LABORATORY DIRECTOR

Maddalena Pezzani

TEST OPERATOR

Pio Acciarri

This document is composed by n°1 page and it can be reproduced only on the whole.
Enclosure: Technical data sheet supplied by the Applicant.

TEST REPORT
according to :

LSFIRE/NC02243
Date: 20-04-2012

ISO 5659-2 + FTIR

Plastics – Smoke generation – Part 2 : Determination of optical density by a single-chamber test

for

prEN 45545-2 Fire protection of railway vehicle
Part 2 - Requirements for fire behaviour of materials and components

Applicant:
3M TILTON
1 Paper Trail
USA - Tilton, N.H.

Denomination of the product : **THERMA VOLT**

Description and characteristics : high temperature paper
thickness: 0.127 mm; weight: 186 g/m²; density: 1506 kg/m³.

Use : electrical insulation

Conditioning: T = (23 ± 2)°C and R.H. = (50 ± 5)% for 88h minimum

Test Methods :

- Determination of optical density by a single chamber test
Operating conditions according to ISO Standard 5659-2 (2006)
- Toxicity of fire effluents measured in a single chamber test
Operating conditions according to Annex C method 1 of prEN 45545-2 : 2010: Testing procedure for analysis of toxic gases

MAIN TEST RESULTS (*)

<u>Description</u>	25 kW/m2 with pilot flame			
	Test n° 1	Test n° 2	Test n° 3	Average
Maximum specific optical density (Ds max)	2.34	2.81	2.47	2.54
Specific optical density at 4 min (D _s 4)	2.34	1.98	2.26	2.19
VOF4	3.23	4.39	3.20	3.60
CIT _G at 4 min	0.0025	0.0026	0.0025	0.0025
CIT _G at 8 min	0.0044	0.0046	0.0044	0.0045

(*) For the other test results see the attached Smoke density and Toxicity reports.

These results relate only to the behaviour of the product under the conditions of test method.
They are not intended to be the sole criterion for the assessment of the performance under real fire conditions.

Controguerra, 04-05-2012

LABORATORY DIRECTOR

Maddalena Pezzani

TEST OPERATOR

Claudio Baiocchi

This document is composed by n°3 page (with Smoke density Report + Toxicity Report) and it can be reproduced only on the whole.
Enclosure: Technical data sheet supplied by the Applicant.

Smoke density

Report according to:


ISO 5659-2

Determination of smoke density by a single chamber test

Parameter	TEST CONDITIONS										
	25 kW/m ² no pilot flame				25 kW/m ² with pilot flame			50 kW/m ² no pilot flame			
Test 1	Test 2	Test 3	Average	Test 1	Test 2	Test 3	Average	Test 1	Test 2	Test 3	Average
T min (%)				96.0040	95.2196	95.7910	95.6716				
Ds max				2.34	2.81	2.54	2.54				
Time Tmin (s)				240	290	315	282				
Ds 10min				1.11	0.93	0.80	0.95				
Ds 4min				2.34	1.98	2.26	2.19				
VOF4				3.23	4.39	3.20	3.60				
Tr residual (%)				99.9	99.9	99.9	99.9				
Dsm corr.				2.28	2.75	2.41	2.48				
Ds averaged				0.91	1.05	0.90	0.95				
T ignition (s)				NI	NI	NI	NI				
End of flame (s)				-	-	-	-				
Test duration (min)				20	20	20	20				
Sample mass (g)				1.189	1.149	1.162	1.167				
Initial mass (g)				1.454	1.431	1.427	1.437				
Final mass (g)				1.372	1.350	1.337	1.353				
Mass loss (g)				0.082	0.081	0.090	0.084				
Tini chamber (°C)				36.0	43.0	42.5	40.5				
Tfin chamber (°C)				45.6	49.0	49.9	48.2				

Remarks:

NI : No Ignition



This document is composed by n°3 page and it can be reproduced only on the whole.
 Enclosure: Technical data sheet supplied by the Applicant.

Toxicity

Report according to:

ISO 5659-2 + FTIR

Toxicity of fire effluents measured in single chamber test

Qualitative analysis

Gas species detected

TEST CONDITIONS											
Test 1	25 kW/m ² no pilot flame	Test 2	Test 3	Test 1	25 kW/m ² with pilot flame	Test 2	Test 3	Test 1	50 kW/m ² no pilot flame	Test 2	Test 3
					Carbon monoxide (CO)						
					Carbon dioxide (CO ₂)						

Quantitative analysis of carbon monoxide (CO)

Parameter	TEST CONDITIONS			TEST CONDITIONS			TEST CONDITIONS			Test 1	25 kW/m ² no pilot flame	Test 2	Test 3	Average	
	Test 1	25 kW/m ² no pilot flame	Test 2	Test 3	Average	Test 1	25 kW/m ² with pilot flame	Test 2	Test 3	Average	Test 1	50 kW/m ² no pilot flame	Test 2	Test 3	Average
CITG at 4min					20.1		20.9		18.6	19.9					
CITG at 8min					25.9		28.9		27.8	27.5					

Quantitative analysis of carbon dioxide (CO₂)

Parameter	TEST CONDITIONS			TEST CONDITIONS			TEST CONDITIONS			Test 1	25 kW/m ² no pilot flame	Test 2	Test 3	Average	
	Test 1	25 kW/m ² no pilot flame	Test 2	Test 3	Average	Test 1	25 kW/m ² with pilot flame	Test 2	Test 3	Average	Test 1	50 kW/m ² no pilot flame	Test 2	Test 3	Average
CITG at 4min					1151.3		1222.2		1232.8	1202.1					
CITG at 8min					2586.8		2638.5		2529.3	2584.9					

Conventional Index of Toxicity according to prEN 45545-2

Parameter	TEST CONDITIONS				TEST CONDITIONS				TEST CONDITIONS						
	Test 1	25 kW/m ² no pilot flame	Test 2	Test 3	Average	Test 1	25 kW/m ² with pilot flame	Test 2	Test 3	Average	Test 1	50 kW/m ² no pilot flame	Test 2	Test 3	Average
CIT _G at 4min					0.0025		0.0026		0.0025	0.0025					
CIT _G at 8min					0.0044		0.0046		0.004	0.0045					

This document is composed by n°3 page and it can be reproduced only on the whole.
Enclosure: Technical data sheet supplied by the Applicant.